

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM694		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A				
Property Owner MILLER TRAVIS					Phone #					
Mailing Address 951 LOG CABIN LN					1. Well Location					
City BELGIUM					State WI		Zip Code 53004		Fire # (if avail.)	
County Ozaukee					Co. Permit #		Notification # 10217244701		Town of BELGIUM 5180	
Completed 04-16-2026					Street Address or Road Name and Number					
					LOWER LAKEVIEW RIDGE RD					
Well Constructor (Business Name)					Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)	
HYINK WELL DRILLING INC					479				43.46643 °N -87.80728 °W	
Address N6250 ALPINE RD							Well Plan Approval #		Method Code	
SHEBOYGAN FALLS WI 53085							Approval Date (mm-dd-yyyy)		GPS008	
Hicap Permanent Well #					Common Well #		Specific Capacity		SW NE Section Township Range	
							0.9		or Govt Lot # 36 12 N 22 E	
3. Well serves 1 # of HOME					Hicap Well ? No		2. Well Type New Well			
Private, potable					Hicap Property ? No		of previous unique well # constructed in			
Heat Exchange ___ # of drillholes					Hicap Potable ? No		Reason for replaced or reconstructed well ?			
							Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE										
5. Drillhole Dimensions and Construction Method										
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock			
6	Surface	142	No Rotary - Mud Circulation				No			
			No Rotary - Air				Yes			
			No Rotary - Air & Foam				No			
			Yes Drill-Through Casing Hammer							
			No Reverse Rotary							
			No Cable-tool Bit ___ in. dia...				No			
			No Dual Rotary				No			
			No Temp. Outer Casing ___ in. dia							
			No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology										
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)		
	F	F-FILL				Surface		1		
	C	C-CLAY				1		55		
	Y	Y-SAND & GRAVEL				55		63		
	L	L-LIMESTONE/DOLOMITE				63		142		
6. Casing, Liner, Screen										
Dia. (in.)	Material, Weight, Specification				From (ft.)		To (ft.)			
	Manufacturer & Method of Assembly									
6	6.625X.280A53B EWBE MV 20' BLACK STEEL				Surface		63			
Dia. (in.)	Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material										
Method MOUNDED										
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				
#8 BENTONITE		Surface								1 S
9. Static Water Level										
41 ft. below ground surface										
10. Pump Test										
Pumping level 55 ft. below surface										
Pumping at 12 GP M for 2 Hrs.										
Pumping Method ? Airlift										
11. Well Is										
20 in. above grade										
Developed ? Yes										
Disinfected ? Yes										
Capped ? Yes										
12. Notified Owner of need to fill & seal ? No										
Filled & Sealed Well(s) as needed? No										
13. Constructor / Supervisory Driller										
Lic #		Date Signed								
RJH		7432		04-20-2026						
Drill Rig Operator		Lic or Reg #		Date Signed						
TJH		3854		04-20-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary	=	32

Comment:

Created On: 04-20-2026

Updated On: 05-13-2026

Review Status: APPROVED