Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM694

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER TRAVIS	Phone #
Mailing Address: 951 LOG CABIN LN	
City: BELGIUM	State: WI Zip Code: 53004
County: Ozaukee	Co. Permit #:	Notification #: 10217244701	Completed: 04-16-2026
Well Constructor (Business Name): HYINK WELL DRILLING INC	Lic. #: 479	Facility ID # (Public Wells):
Address: N6250 ALPINE RD SHEBOYGAN FALLS WI 53085	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.9

1. Well Location

Town of BELGIUM	Fire # (if avail.): 5180
Street Address or Road Name and Number: LOWER LAKEVIEW RIDGE RD	
Subdivision Name:	Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.46643 °N -87.80728 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 36	Township: 12 N	Range: 22 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
F	F-FILL	Surface	1
C	C-CLAY	1	55
Y	Y-SAND & GRAVEL	55	63
L	L-LIMESTONE/DOLOMITE	63	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625X.280A53B EWBE MV 20' BLACK STEEL	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		1 S

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJH	7432	04-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TJH	3854	04-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary	=	32

Comment:

Created On: 04-20-2026 Updated On: 05-13-2026 Review Status: APPROVED