Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM698

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: POPELKA, DAVID	Phone #
Mailing Address: 13540 TREE LINE RD	
City: CABLE	State: WI — Zip Code: 54821
County: Bayfield	Co. Permit #: — Notification #: 10217064601 — Completed: 04-10-2026
Well Constructor (Business Name): ANDERSON, PAUL R	Lic. #: 4681 — Facility ID # (Public Wells):
Address: PAUL R ANDERSON WELL DRILLING, 60995 WIBERG RD, ASHLAND WI 54806	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of CABLE	Fire # (if avail.): 13540
Street Address or Road Name and Number: TREE LINE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.205 °N -91.2899 °W	Method Code: GPS008
NW SE or Govt Lot #:	Section: 18 — Township: 43 N — Range: 7 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NOT ENOUGH WATER IN OLD WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	6
4	6	74

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	S	S	T-TAN/BROWN V-NON-CAVING S-SAND S-SANDY	Surface	20
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	20	71
T	W	S	S	T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY	71	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	4"ID T&D ASTM A-53-B WEATLAND	Surface	71
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	10 SLOT SCREEN 4X2 KPACK	71	74

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	6	4 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

NOT ENOUGH WATER IN OLD WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
PA	4681	04-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RH	8996	04-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Variance ID	Variance or Exception Type	Date	Reason
84710	Landfill Variance	04/06/2026	

Created On: 04-20-2026 Updated On: 10-15-2026 Review Status: APPROVED