

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM709		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BANOVEC, MICHAEL						Phone # (608)547-7013		1. Well Location				Fire # (if avail.)									
Mailing Address 1720 COUNTY RD N						Town of STRONGS PRAIRIE						1720									
City FRIENDSHIP						State WI		Zip Code 53934				Street Address or Road Name and Number COUNTY RD N									
County Adams		Co. Permit #		Notification # 10223108202		Completed 04-18-2026		Subdivision Name				Lot # 100		Block #							
Well Constructor (Business Name) REICHHOFF, RODNEY J				Lic. # 7202		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0508 °N -89.8792 °W				Method Code SCR002							
Address W8740 EVERGREEN DR OXFORD WI 53952				Well Plan Approval #		NE NE		Section 10		Township 18 N		Range 5 E		or Govt Lot #							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.8				2. Well Type Replacement									
Hicap Property ? No				Hicap Potable ? No		Reason for replaced or reconstructed well ? HOLE IN PIPE				Construction Type Jetted											
3. Well serves 1 # of HOME				Private, potable		Heat Exchange ___ # of drillholes				of previous unique well # constructed in											
4. Potential Contamination Sources - ON REVERSE SIDE												5. Drillhole Dimensions and Construction Method									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
2		Surface		63		No Rotary - Mud Circulation				No											
1.25		63		67		No Rotary - Air				No											
						No Rotary - Air & Foam				No											
						No Drill-Through Casing Hammer															
						No Reverse Rotary															
						Yes Cable-tool Bit 1.25in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen												8. Geology									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
2		WHEATLAND ERW ASTM A 53 3.75# COUPLED				Surface		63		R S		S-SAND		Surface		25					
										M Y		R-RED C-CLAY		25		42					
												M-MEDIUM Y-SAND & GRAVEL		42		67					
7. Grout or Other Sealing Material												9. Static Water Level				11. Well Is					
Method MOUNDED												32 ft. below ground surface				18 in. above grade					
Kind of Sealing Material GRANULAR BENTONITE												From (ft.) Surface		To (ft.) 20		# Sacks Cement 1		10. Pump Test			
Developed ? Yes												Disinfected ? Yes				Capped ? Yes					
Filled & Sealed Well(s) as needed? Yes												Pumping level 32 ft. below surface				Pumping at 10 GP M for 2 Hrs.					
Pumping Method ? Test Pump												12. Notified Owner of need to fill & seal ? Yes				13. Constructor / Supervisory Driller					
Lic # 7202												Date Signed 04-21-2026				RR					
Drill Rig Operator												Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		66	POWTS dispersal component (soil absorption unit or mound)		77

Comment:

Created On: 04-20-2026

Updated On: 05-14-2026

Review Status: APPROVED