Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM709

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BANOVEC, MICHAEL			Phone #: (608)547-7013
Mailing Address: 1720 COUNTY RD N			
City: FRIENDSHIP	State: WI	Zip Code: 53934	
County: Adams	Co. Permit #:	Notification #: 10223108202	Completed: 04-18-2026

Well Constructor (Business Name): REICHHOFF, RODNEY J	Lic. #: 7202	Facility ID # (Public Wells):	
Address: W8740 EVERGREEN DR OXFORD WI 53952		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of STRONGS PRAIRIE

Fire # (if avail.): 1720

Street Address or Road Name and Number: COUNTY RD N

Subdivision Name:	Lot #: 100	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.0508 °N -89.8792 °W

Method Code: SCR002

NE	NE	Section	Township	Range
or Govt Lot #		10	18 N	5 E

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: HOLE IN PIPE

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	63
1.25	63	67

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 1.25in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	25
R		C		R-RED C-CLAY	25	42
	M	Y		M-MEDIUM Y-SAND & GRAVEL	42	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A 53 3.75# COUPLED	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	80 GA STAINLESS STEEL 4' POINT	63	67

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	1

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		66	POWTS dispersal component (soil absorption unit or mound)		77

Comment:

Created On: 04-20-2026 Updated On: 10-15-2026 Review Status: APPROVED