

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM710		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner REED LORI & PAUL					Phone # (608)220-9581		1. Well Location				Fire # (if avail.)			
Mailing Address 379 FISH COURT							Town of ADAMS				379			
City OXFORD					State WI		Zip Code 53952				Street Address or Road Name and Number FISH CT			
County Adams		Co. Permit #		Notification # 10227143801		Completed 04-17-2026		Subdivision Name			Lot # 100		Block #	
Well Constructor (Business Name) REICHHOFF, RODNEY J				Lic. # 7202		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.7862 °N -89.6556 °W				Method Code SCR002		
Address W8740 EVERGREEN DR OXFORD WI 53952				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 15 15 N 7 E		2. Well Type Replacement						
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well # constructed in						
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ? HOLE IN PIPE						
Private, potable				Hicap Potable ? No		Construction Type Jetted								
Heat Exchange ___ # of drillholes														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
2		Surface		63		No Rotary - Mud Circulation			No					
1.25		63		67		No Rotary - Air			No					
						No Rotary - Air & Foam			No					
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						Yes Cable-tool Bit 1.25in. dia...			No					
						No Dual Rotary			No					
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
R S		S-SAND				Surface		35						
R C		R-RED C-CLAY				35		42						
Y		Y-SAND & GRAVEL				42		67						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
2		WHEATLAND ERW ASTM A 53 3.75# COUPLED				Surface		63						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
1.25		80 GA STAINLESS STEEL 4' POINT				63		67						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
GRANULAR BENTONITE		Surface		54		2 S								
9. Static Water Level														
32 ft. below ground surface														
10. Pump Test														
Pumping level 54 ft. below surface														
Pumping at 10 GP M for 2 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
16 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller														
Lic #		Date Signed												
RR		7202		04-21-2026										
Drill Rig Operator		Lic or Reg #		Date Signed										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		63	POWTS dispersal component (soil absorption unit or mound)		84

Comment:

Created On: 04-20-2026

Updated On: 05-14-2026

Review Status: APPROVED