

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM713		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JO ANN K UNSETH						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address S5406 WAPP HILL RD						Town of HARMONY						S5406							
City GENOA						State WI		Zip Code 54632				Street Address or Road Name and Number WAPP HILL RD							
County Vernon		Co. Permit #		Notification # 10217014301		Completed 04-20-2026		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) SCHAITEI, JAKE J				Lic. # 3822		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.535 °N -91.0925 °W				Method Code SCR002					
Address TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603				Well Plan Approval #		NE NE		Section 9		Township 12 N		Range 6 W							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type Replacement									
										of previous unique well # constructed in 1940									
										Reason for replaced or reconstructed well ? BACTERIA AND NITRATES									
3. Well serves 1 # of HOME				Hicap Well ? No						Construction Type Drilled									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 360			No Rotary - Mud Circulation				No				R V C		R-RED V-NON-CAVING C-CLAY		Surface 15				
6 360 500			No Rotary - Air				No				T H L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE		15 188				
			Yes Rotary - Air & Foam				Yes				T S N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE		188 265				
			No Drill-Through Casing Hammer								G H H		G-GRAY H-HARD/FIRM H-SHALE		265 304				
			No Reverse Rotary								G H N		G-GRAY H-HARD/FIRM N-SANDSTONE		304 500				
			No Cable-tool Bit ___ in. dia...				No												
			No Dual Rotary				No												
			No Temp. Outer Casing ___ in. dia																
			No Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		334 ft. below ground surface				18 in. above grade					
6		NEW PE BLACK STEEL ASTM A 53 A 19.85 280 WALL WELD WHEATLAND USA PIPE				Surface		360		10. Pump Test				Developed ? Yes					
										Pumping level 460 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 3 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes					
Method TREMIE PIPE - PUMPED														PUMP INSTALLER WILL					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
NEAT CEMENT GROUT				Surface		360		200 S		PUMP INSTALLER WILL									
13. Constructor / Supervisory Driller														Lic #		Date Signed			
JS														3822		04-20-2026			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-20-2026

Updated On: 05-13-2026

Review Status: APPROVED