Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM714

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BACKMAN. LARS	Phone #: (847)815-8311
Mailing Address: 27635 295TH AVE	
City: HOLCOMBE	State: WI — Zip Code: 54745

County	Co. Permit #	Notification #	Completed
Chippewa	20260029	10198309401	04-03-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WILLMARTH, TRAVIS	6233	

Address: WILLMARTH WELL DRILLING LLC 29350 295TH ST HOLCOMBE WI 54745-9739

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		3

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of LAKE HOLCOMBE

Fire # (if avail.): 27635

Street Address or Road Name and Number: 295TH AVE

Subdivision Name	Lot #	Block #
HOLCOMBE SHORES	3	

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.26558 °N -91.11949 °W	SCR002

SW SE or Govt Lot #	Section	Township	Range
	9	32 N	6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-A53B BLK P.E. 6.625 O.D. X.280 WALL WHEATLAND	Surface	40.6
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ALLOY MACHINE-STAINLESS-.010	39	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	6233	04-05-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Landfill		1200	Sewer - Building Sanitary		25

Comment:

Created On: 04-20-2026 Updated On: 05-14-2026 Review Status: APPROVED