Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM716

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DOCKSEY, NICHOLAS AND ANGELA	Phone #: (715)271-6504
Mailing Address: 4453 115TH ST	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729

County	Co. Permit #	Notification #	Completed
Chippewa	20260008	10145687001	04-06-2026

Well Constructor (Business Name): WILLMARTH, TRAVIS	Lic. #: 6233
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: WILLMARTH WELL DRILLING LLC 29350 295TH ST HOLCOMBE WI 54745-9739	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 7.5	

3. Well serves 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of LAFAYETTE

Fire # (if avail.): 17952

Street Address or Road Name and Number: 54TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.92211 °N -91.30804 °W	SCR002

NE SE or Govt Lot #	Section	Township	Range
	11	28 N	8 W

2. Well Type New Well
of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	49

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	35
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	35	49

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-A53B BLK P.E. 6.625 O.D. X.280 WALL WHEATLAND	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ALLOY MACHINE-STAINLESS-.010	40	49

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 29.6 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	6233	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		100
POWTS dispersal component (soil absorption unit or mound)		50
Building Drain - Sanitary		20

Type	Qualifier	Distance
Landfill		1200
Sewer - Building Sanitary		20
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-20-2026 Updated On: 05-14-2026 Review Status: APPROVED