Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM717

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ASHLEY, ADAM	Phone #: (715)271-6504
Mailing Address: 12820 30TH AVE	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729

County	Co. Permit #	Notification #	Completed
Chippewa	20250207	10048040702	04-13-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WILLMARTH, TRAVIS	6233	

Address: WILLMARTH WELL DRILLING LLC 29350 295TH ST HOLCOMBE WI 54745-9739

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #:

Common Well #:

Specific Capacity: 6

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of EAGLE POINT

Fire # (if avail.): 15571

Street Address or Road Name and Number: 102ND COURT

Subdivision Name	Lot #	Block #
CSM 5595	3	

Latitude / Longitude in Decimal Degree (DD): 44.99064 °N -91.35571 °W

Method Code: SCR002

SW	SE	Section	Township	Range
or Govt Lot #		16	29 N	8 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	40
T	Q	Y	M	T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL M-SILTY	40	60
T	Q	X	M	T-TAN/BROWN Q-CAVING X-SAND & CLAY M-SILTY	60	75
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	75	79
T	Q	G		T-TAN/BROWN Q-CAVING G-GRAVEL/STONES	79	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-A53B BLK P.E. 6.625 O.D. X.280 WALL WHEATLAND	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	20	

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	6233	04-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		75
POWTS dispersal component (soil absorption unit or mound)		100
Building Drain - Sanitary		25

Type	Qualifier	Distance
Landfill		1200
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 04-20-2026 Updated On: 05-14-2026 Review Status: APPROVED