Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM718

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OSTERTAG, PAUL AND CANDACE	Phone #: (715)271-6504
Mailing Address: 1830 BLUEBERRY DR	
City: PLOVER	State: WI — Zip Code: 54467

County	Co. Permit #	Notification #	Completed
Eau Claire	35176	10198309403	04-17-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WILLMARTH, TRAVIS	6233	

Address: WILLMARTH WELL DRILLING LLC 29350 295TH ST, HOLCOMBE WI 54745-9739

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		1

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of WASHINGTON

Fire # (if avail.): 183

Street Address or Road Name and Number: 183 ROMA ST

Subdivision Name	Lot #	Block #
FIRENZE	57	

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.7299 °N -91.50579 °W	SCR002

SW SW or Govt Lot #	Section	Township	Range
	17	26 N	9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	36
6	36	130

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 8in. dia...	No
No	Dual Rotary	Yes
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 9depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY	Surface	8
T	V	N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE	8	20
T	V	N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE	20	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD-A53B BLK P.E. 6.625 O.D. X.280 WALL WHEATLAND	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GROUT DISPLACEMENT (PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	36	9 S

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 15 GP M for 36 Hrs.

Pumping Method ? Test Pump

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW	6233	04-19-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Landfill		1200
			Sewer - Building Sanitary		25

Comment:

Created On: 04-20-2026 Updated On: 10-15-2026 Review Status: APPROVED