

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM718		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner OSTERTAG, PAUL AND CANDACE						Phone # (715)271-6504		1. Well Location				Fire # (if avail.)									
Mailing Address 1830 BLUEBERRY DR						Town of WASHINGTON						183									
City PLOVER						State WI		Zip Code 54467				Street Address or Road Name and Number 183 ROMA ST									
County Eau Claire		Co. Permit # 35176		Notification # 10198309403		Completed 04-17-2026		Subdivision Name FIRENZE				Lot # 57		Block #							
Well Constructor (Business Name) WILLMARTH, TRAVIS				Lic. # 6233		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7299 °N -91.50579 °W				Method Code SCR002							
Address WILLMARTH WELL DRILLING LLC 29350 295TH ST HOLCOMBE WI 54745-9739				Well Plan Approval #		SW SW		Section 17		Township 26 N		Range 9 W									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well											
Hicap Well ? No				Hicap Property ? No		Hicap Potable ? No				Reason for replaced or reconstructed well ?											
Private, potable				Drillhole		Heat Exchange ___ # of drillholes				Construction Type Drilled											
3. Well serves 1 # of HOME																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		36		<u>No</u> Rotary - Mud Circulation				<u>No</u>		T V X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY		Surface		8			
6		36		130		<u>No</u> Rotary - Air				<u>No</u>		T V N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE		8		20			
						<u>No</u> Rotary - Air & Foam				<u>No</u>		T V N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE		20		130			
						<u>No</u> Drill-Through Casing Hammer															
						<u>No</u> Reverse Rotary															
						<u>Yes</u> Cable-tool Bit 8in. dia...				<u>No</u>											
						<u>No</u> Dual Rotary				<u>Yes</u>											
						<u>Yes</u> Temp. Outer Casing 8in. dia															
						<u>Yes</u> Removed? 9depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		55 ft. below ground surface				26 in. above grade							
6		STD-A53B BLK P.E. 6.625 O.D. X.280 WALL WHEATLAND				Surface		36		10. Pump Test Pumping level 70 ft. below surface Pumping at 15 GP M for 36 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method GROUT DISPLACEMENT (PLUG)														12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
NEAT CEMENT GROUT				Surface		36		9 S													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
TW														6233		04-19-2026					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Landfill		1200
			Sewer - Building Sanitary		25

Comment:

Created On: 04-20-2026

Updated On: 05-26-2026

Review Status: APPROVED