

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM720		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner METTLER, TOM						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 669 DEERWOOD DR								Town of LORAIN				3518									
City HUDSON						State WI		Zip Code 54016				Street Address or Road Name and Number 25TH ST									
County Polk		Co. Permit #		Notification # 10225092201		Completed 04-15-2026		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) CHELL WELL DRILLING				Lic. # 22		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.71515 °N -92.20588 °W				Method Code SCR002							
Address 1471 345TH AVE FREDERIC WI 54837				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 3 37 N 15 W				2. Well Type Replacement											
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? DRY/CASING FAILURE				Construction Type Drilled											
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		150		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						P		P-HARDPAN		Surface		146			
												S		S-SAND		146		150			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface				15 in. above grade							
6		STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD				Surface		146		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes							
4		TELESCOPED STAINLESS STEEL 15 SLOT				146		150		Pumping at 20 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														Pumping Method ? Airlift				12. Notified Owner of need to fill & seal ? Yes			
Method MOUNDED																		Filled & Sealed Well(s) as needed? Yes			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
GRANULAR BENTONITE				Surface						DJC				6846		04-20-2026					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	40

Comment:

Created On: 04-20-2026

Updated On: 05-05-2026

Review Status: APPROVED