Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM722

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHROCK, AUSTIN & CASSONDRA	Phone #
Mailing Address: 14783W STATE HWY 77	
City: HAYWARD	State: WI / Zip Code: 54843
County: Sawyer	Co. Permit #: / Notification #: 10232505201 / Completed: 04-20-2026
Well Constructor (Business Name): BUTTERFIELD INC	Lic. #: 7115 / Facility ID # (Public Wells):
Address: 14346 W ST RD 77 HAYWARD WI 54843-9790	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 0.7

1. Well Location

Town of HAYWARD				Fire # (if avail.): 14783W
Street Address or Road Name and Number: STATE HWY 77				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 46.01355 °N -91.43034 °W				Method Code: GPS008
SE	SE	Section: 24	Township: 41 N	Range: 9 W
or Govt Lot #				

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: FAILED

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NAS PVC SDR17 250PSI ASTM F480	Surface	134
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	10 CONTINUOUS SLOT STAINLESS STEEL	134	140

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
TD-16 BENTONITE GROUT	Surface	131	9 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	1
		Y	C	Y-SAND & GRAVEL C-CLAYEY	1	10
		C		C-CLAY	10	50
	M	S	C	M-MEDIUM S-SAND C-CLAYEY	50	60
	N	S	M	N-FINE S-SAND M-SILTY	60	70
	M	X	G	M-MEDIUM X-SAND & CLAY G-W/GRAVEL/STONES	70	85
	A	S		A-COARSE S-SAND	85	120
	A	Y		A-COARSE Y-SAND & GRAVEL	120	130
	A	S		A-COARSE S-SAND	130	140

9. Static Water Level	11. Well Is
83 ft. below ground surface	14 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 97 ft. below surface	Disinfected ? Yes
Pumping at 10 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAB	6349	04-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JSM	7418	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75	Septic or Holding, or POWTS Tank	=	60

Comment:

Created On: 04-21-2026 Updated On: 10-15-2026 Review Status: APPROVED