Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM732

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GIBEAULT, MARK	Phone #
Mailing Address: W6250 LAKE ELLEN DR,	
City: CASCADE	State: WI — Zip Code: 54311

County	Co. Permit #	Notification #	Completed
Marinette	1	10230020502	04-20-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
VAN DE YACHT LEO WELL DRILLING INC	6097	

Address: 1267 LAKEVIEW DR, GREEN BAY WI 54313

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Fire # (if avail.): N8603

Town of STEPHENSON

Street Address or Road Name and Number: PARKWAY

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 45.2749 °N -88.2225 °W — Method Code: GPS008

SW	SW	Section	Township	Range
or Govt Lot #	2	32 N	18 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
SANDPOINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	281

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	39
		X	M	X-SAND & CLAY M-SILTY	39	58
		C		C-CLAY	58	65
		X	M	X-SAND & CLAY M-SILTY	65	89
		Q		Q-GRANITE	89	281

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END WELDED ASTM A 53B 18 97# PER FT NUCOR PIPE	Surface	89
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
6 ft. below ground surface

10. Pump Test
Pumping level 250 ft. below surface
Pumping at 2 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BEN SEAL	Surface	89	2 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes
TO BE DONE BY PUMP INSTALLER

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLV	6378	04-21-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KZ	7365	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	95	Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-21-2026 Updated On: 05-13-2026 Review Status: APPROVED