

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM732		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GIBEAULT, MARK						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W6250 LAKE ELLEN DR,						Town of STEPHENSON						N8603			
City CASCADE						State WI		Zip Code 54311				Street Address or Road Name and Number PARKWAY			
County Marinette		Co. Permit # 1		Notification # 10230020502		Completed 04-20-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) VAN DE YACHT LEO WELL DRILLING INC				Lic. # 6097		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.2749 °N -88.2225 °W				Method Code GPS008	
Address 1267 LAKEVIEW DR GREEN BAY WI 54313				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 2 32 N 18 E		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? SANDPOINT				Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock						
6		Surface		281		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
S		S-SAND				Surface		39							
X M		X-SAND & CLAY M-SILTY				39		58							
C		C-CLAY				58		65							
X M		X-SAND & CLAY M-SILTY				65		89							
Q		Q-GRANITE				89		281							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLACK STEEL PLAIN END WELDED ASTM A 53B 18 97# PER FT NUCOR PIPE				Surface		89							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
BEN SEAL		Surface		89		2 S									
9. Static Water Level															
6 ft. below ground surface															
10. Pump Test															
Pumping level 250 ft. below surface															
Pumping at 2 GP M for 2 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
TO BE DONE BY PUMP INSTALLER															
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
TLV		6378		04-21-2026											
Drill Rig Operator		Lic or Reg #		Date Signed											
KZ		7365		04-21-2026											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	95	Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-21-2026

Updated On: 05-13-2026

Review Status: APPROVED