Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM749

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RIVERS, NATALIE	Phone #
Mailing Address: W10352 ALPINE DRIVE SOUTH	
City: ELROY	State: WI — Zip Code: 53929
County: Juneau	Co. Permit #: — Notification #: 10217692301 — Completed: 04-20-2026
Well Constructor (Business Name): MARSHALL WELL DRILLING CORP	Lic. #: 6946 — Facility ID # (Public Wells):
Address: 3774 ST RD 13 WISCONSIN DELLS WI 53965-8906	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 20

1. Well Location

Town of PLYMOUTH	Fire # (if avail.): W10352
Street Address or Road Name and Number: ALPINE DRIVE SOUTH	
Subdivision Name:	Lot #: 4 — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8103 °N -90.2849 °W	Method Code: GPS008
NE SW or Govt Lot #:	Section: 5 — Township: 15 N — Range: 2 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.875	Surface	99
6	99	220

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
Yes	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 13depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	C-CLAY	Surface	8
H	H-SHALE	8	30
N	N-SANDSTONE	30	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL PIPE ASTM A-53 GR.B 18.97 LBS/FT WHEATLAND STEEL	Surface	99
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
119 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 20 GP M for 72 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	99	35 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JLJ	7213	04-22-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RGW	7349	04-22-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	100	Sewer - Building Sanitary		15
Building Drain - Sanitary	>	8	Septic or Holding, or POWTS Tank		17

Comment:

Variance ID	Variance or Exception Type	Date	Reason
83521	Separation Distance Variance	03/20/2026	

Created On: 04-21-2026 Updated On: 05-14-2026 Review Status: APPROVED