# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACM754

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: DOUBLE D CONSTRUCTION | | | Phone # |
| Mailing Address: 1010 88TH AVE | | | |
| City: KENOSHA | State: WI | Zip Code: 53144 | |
| County: Kenosha | Co. Permit #: | Notification #: 10207782301 | Completed: 04-15-2026 |

| | | | |
|---|---|---|---|
| Well Constructor (Business Name): SWEENEY, KENNETH R | Lic. #: 583 | Facility ID # (Public Wells): | |
| Address: KEN SWEENEY WELL DRILLING & PUMPS 11221 W ST MARTINS RD FRANKLIN WI 53132-2331 | | Well Plan Approval #: | Approval Date (mm-dd-yyyy): |
| Hicap Permanent Well #: | Common Well #: | Specific Capacity: 1.2 | |

**1. Well Location**

Town of PARIS

Fire # (if avail.)

Street Address or Road Name and Number: 15204 12TH STREET

| | | |
|---|---|---|
| Subdivision Name | Lot # | Block # |

| | | | | |
|---|---|---|---|---|
| Latitude / Longitude in Decimal Degree (DD): 42.6439 °N -87.9941 °W | Method Code: GPS008 | | | |
| SE SE or Govt Lot # | Section: 10 | Township: 2 N | Range: 21 E | |

**2. Well Type** New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

**3. Well serves** 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 222 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | Yes |
| No | Rotary - Air & Foam ..... | No |
| Yes | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| T | | C | | T-TAN/BROWN C-CLAY | Surface | 16 |
| U | | C | | U-BLUE C-CLAY | 16 | 118 |
| U | | C | S | U-BLUE C-CLAY S-SANDY | 118 | 205 |
| | | L | | L-LIMESTONE/DOLOMITE | 205 | 222 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | 18.97#/FT ASTM A53B WHEATLAND WELDED | Surface | 205 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | | |

**9. Static Water Level**

78 ft. below ground surface

**10. Pump Test**

Pumping level 120 ft. below surface

Pumping at 50 GP M for 2 Hrs.

Pumping Method ? Airlift

**11. Well Is**

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| KS | 583 | 04-21-2026 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| MW | 7359 | 04-21-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

Comment:

Created On: 04-21-2026 Updated On: 05-14-2026 Review Status: APPROVED