Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM759

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: POOLER, RUSS	Phone #: (763)486-7800
Mailing Address: 3215 E OLD HWY 105	
City: SUPERIOR	State: WI — Zip Code: 54880
County: Douglas	Co. Permit #:
Notification #: 10225044001	Completed: 04-16-2026
Well Constructor (Business Name): WAYNE HOLLY WELL DRILLING LLC	Lic. #: 9031
Facility ID # (Public Wells):	
Address: 71385 HOOVER LINE RD, IRON RIVER WI 54847	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of SUPERIOR			Fire # (if avail.): 3215
Street Address or Road Name and Number: E OLD HWY 105			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 46.65982 °N -92.1394 °W			Method Code: SCR002
NW NW or Govt Lot #	Section: 9	Township: 48 N	Range: 14 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	200

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	H	C		R-RED H-HARD/FIRM C-CLAY	Surface	20
R	S	C		R-RED S-SOFT/LOOSE C-CLAY	20	80
R	M	P	S	R-RED M-MEDIUM P-HARDPAN S-SANDY	80	130
R	M	P		R-RED M-MEDIUM P-HARDPAN	130	170
R	M	P	S	R-RED M-MEDIUM P-HARDPAN S-SANDY	170	195
T	A	S		T-TAN/BROWN A-COARSE S-SAND	195	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR17, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED	Surface	196
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	FLATBOTTOM STAINLESS STEEL 10 SLOT	196	200

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL BENTONITE	Surface	190	19 S

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 191 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	7218	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed
DH	8983	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 04-21-2026 Updated On: 10-15-2026 Review Status: APPROVED