

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM759		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner POOLER, RUSS					Phone # (763)486-7800			1. Well Location			Fire # (if avail.)						
Mailing Address 3215 E OLD HWY 105								Town of SUPERIOR			3215						
City SUPERIOR					State WI		Zip Code 54880					Street Address or Road Name and Number E OLD HWY 105					
County Douglas		Co. Permit #		Notification # 10225044001		Completed 04-16-2026		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) WAYNE HOLLY WELL DRILLING LLC				Lic. # 9031		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.65982 °N -92.1394 °W			Method Code SCR002						
Address 71385 HOOVER LINE RD IRON RIVER WI 54847				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 9 48 N 14 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		200		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				R H C R-RED H-HARD/FIRM C-CLAY Surface 20 R S C R-RED S-SOFT/LOOSE C-CLAY 20 80 R M P S R-RED M-MEDIUM P-HARDPAN S-SANDY 80 130 R M P R-RED M-MEDIUM P-HARDPAN 130 170 R M P S R-RED M-MEDIUM P-HARDPAN S-SANDY 170 195 T A S T-TAN/BROWN A-COARSE S-SAND 195 200							
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface		20 in. above grade					
5		PVC SDR17, NORTH AMERICAN SPECIALTY, ASTM F480 - GLUED				Surface		196		10. Pump Test Pumping level 191 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Test Pump		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
4		FLATBOTTOM STAINLESS STEEL 10 SLOT				196		200									
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
EZ SEAL BENTONITE				Surface		190		19 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
WH												7218		04-21-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
DH												8983		04-21-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	>	55

Comment:

Created On: 04-21-2026

Updated On: 07-09-2026

Review Status: APPROVED