

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM769		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HAESSLY MICHAEL					Phone #		1. Well Location Village of ROCHESTER Street Address or Road Name and Number BEERE LANE				Fire # (if avail.) 1055			
Mailing Address 1055 BEERE LANE														
City BURLINGTON			State WI		Zip Code 53105		Subdivision Name Lot # Block #							
County Racine		Co. Permit #		Notification # 10232678801		Completed 04-23-2026								
Well Constructor (Business Name) 4-D WATER WELL & PUMP SERVICE LLC			Lic. # 8157		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.7279 °N -88.2032 °W				Method Code GPS008			
Address N82 W28160 MARSHALL DR HARTLAND WI 53029			Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SW		Section 12		Township 3 N		Range 19 E	
							or Govt Lot #							
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes			Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		142		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
T C			T-TAN/BROWN C-CLAY			Surface			25					
T C S			T-TAN/BROWN C-CLAY S-SANDY			25			81					
G C			G-GRAY C-CLAY			81			132					
I L			I-WHITE L-LIMESTONE/DOLOMITE			132			142					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		6 INCH WELDED NEW STEEL PLAIN END .A53 ASTM .280 X 20 MARIUCCI LEAVITT				Surface		142						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE #8 CETCO				Surface				1 S						
9. Static Water Level 58 ft. below ground surface														
10. Pump Test Pumping level 80 ft. below surface Pumping at 25 GP M for 2 Hrs. Pumping Method ? Airlift														
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller				Lic #		Date Signed								
DW				6377		04-24-2026								
Drill Rig Operator				Lic or Reg #		Date Signed								
LM				7824		04-23-2026								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		

Comment: SEPTIC SYSTEM NOT IN

Created On: 04-21-2026

Updated On: 05-22-2026

Review Status: APPROVED