Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM769

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	HAESSLY MICHAEL
Phone #	
Mailing Address	1055 BEERE LANE
City	BURLINGTON
State	WI
Zip Code	53105
County	Racine
Co. Permit #	
Notification #	10232678801
Completed	04-23-2026
Well Constructor (Business Name)	4-D WATER WELL & PUMP SERVICE LLC
Lic. #	8157
Facility ID # (Public Wells)	
Address	N82 W28160 MARSHALL DR HARTLAND WI 53029
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1.1

1. Well Location

Village of ROCHESTER	Fire # (if avail.) 1055
Street Address or Road Name and Number	BEERE LANE
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	42.7279 °N -88.2032 °W
Method Code	GPS008
SE SW or Govt Lot #	
Section	12
Township	3 N
Range	19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		T-TAN/BROWN C-CLAY	Surface	25
T		C	S	T-TAN/BROWN C-CLAY S-SANDY	25	81
G		C		G-GRAY C-CLAY	81	132
I		L		I-WHITE L-LIMESTONE/DOLOMITE	132	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6 INCH WELDED NEW STEEL PLAIN END .A53 ASTM .280 X 20 MARIUCCI LEAVITT	Surface	142
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

58 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE #8 CETCO	Surface		1 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DW	6377	04-24-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LM	7824	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		

Comment: SEPTIC SYSTEM NOT IN

Created On: 04-21-2026 Updated On: 10-15-2026 Review Status: APPROVED