

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM771		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner J & J CUSTOM HOMES / CAMPIONE						Phone # (414)423-9200		1. Well Location				Fire # (if avail.)		
Mailing Address 6600 SCHOOLWAY						City of NEW BERLIN						16866		
City GREENDALE						State WI		Zip Code 53129				Street Address or Road Name and Number W AUTUMN TRACE		
County Waukesha		Co. Permit #		Notification # 10233586401		Completed 04-21-2026		Subdivision Name AUTUMN TRACE			Lot # 5		Block #	
Well Constructor (Business Name) HERR WELL DRILLING INC				Lic. # 672		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.9561 °N -88.1253 °W			Method Code GPS008			
Address W295 HERR RD DOUSMAN WI 53118-9407				Well Plan Approval #		NW NW		Section 27		Township 6 N		Range 20 E		
Approval Date (mm-dd-yyyy)				Heatcap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well				
Heatcap Property ? No				Heatcap Potable ? No		Reason for replaced or reconstructed well ?								
3. Well serves 1 # of HOME				Private, potable		Heat Exchange ___ # of drillholes		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		105		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)				
Z		Z-CLAY & GRAVEL						Surface		58				
N S		N-FINE S-SAND						58		69				
L		L-LIMESTONE/DOLOMITE						69		105				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI				Surface		69						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
GRANULAR BENTONITE		Surface												
9. Static Water Level														
15 ft. below ground surface														
10. Pump Test														
Pumping level 45 ft. below surface														
Pumping at 30 GP M for 2 Hrs.														
Pumping Method ? Airlift														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller														
Lic #		Date Signed												
ALO		6666		04-21-2026										
Drill Rig Operator		Lic or Reg #		Date Signed										
NSD		8132		04-21-2026										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		200	Septic or Holding, or POWTS Tank		82

Comment:

Created On: 04-21-2026

Updated On: 05-14-2026

Review Status: APPROVED