Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM771

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: J & J CUSTOM HOMES / CAMPIONE		Phone #: (414)423-9200
Mailing Address: 6600 SCHOOLWAY		
City: GREENDALE	State: WI	Zip Code: 53129

County	Co. Permit #	Notification #	Completed
Waukesha		10233586401	04-21-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HERR WELL DRILLING INC	672	

Address: W295 HERR RD
DOUSMAN WI 53118-9407

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		1

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

City of NEW BERLIN

Fire # (if avail.): 16866

Street Address or Road Name and Number: W AUTUMN TRACE

Subdivision Name	Lot #	Block #
AUTUMN TRACE	5	

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.9561 °N	-88.1253 °W			GPS008

NW or Govt Lot #	NW	Section	Township	Range
		27	6 N	20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z		Z-CLAY & GRAVEL	Surface	58
	N	S		N-FINE S-SAND	58	69
		L		L-LIMESTONE/DOLOMITE	69	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 30 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
ALO	6666	04-21-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
NSD	8132	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		200	Septic or Holding, or POWTS Tank		82

Comment:

Created On: 04-21-2026 Updated On: 05-14-2026 Review Status: APPROVED