Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM777

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MONDAY, CARLA	Phone #
Mailing Address: PO BOX 192	
City: NEWBURG	State: WI Zip Code: 53060
County: Washington	Co. Permit #:	Notification #: 10155426301	Completed: 04-21-2026
Well Constructor (Business Name): STEFFES, DANIEL J	Lic. #: 6109	Facility ID # (Public Wells):
Address: BADGER WELL DRLG N7900 LOCUST LN MT CALVARY WI 53057	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7

1. Well Location

Town of WAYNE				Fire # (if avail.): 9511
Street Address or Road Name and Number: 9511 TOWNLINE RD				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 43.5375 °N -88.2845 °W				Method Code: GPS008
SE NE or Govt Lot #:	Section: 1	Township: 12 N	Range: 18 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	45
6	45	245

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	Z-CLAY & GRAVEL	Surface	24
L	L-LIMESTONE/DOLOMITE	24	245

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A 53 B EXL TUBE 6.625 X .280 EL 20 PLAIN END	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	45	10 S

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DS	6109	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed
GM	6835	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-21-2026 Updated On: 05-14-2026 Review Status: APPROVED