Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM783

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DUNBAR, DALE	Phone #
Mailing Address: N2321 W PINE CIRCLE	
City: REDGRANITE	State: WI — Zip Code: 54970
County: Waushara	Co. Permit #: — Notification #: 10232728201 — Completed: 04-21-2026
Well Constructor (Business Name): WELLS BY WELCH - BENTLEY WD LLC	Lic. #: 7500 — Facility ID # (Public Wells):
Address: 9403 TRI COUNTY RD, FREMONT WI 54940	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of WARREN				Fire # (if avail.): N2321
Street Address or Road Name and Number: W PINE CIRCLE				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.0633 °N -89.1276 °W				Method Code: OTH001
SW / NW or Govt Lot #:	Section: 6	Township: 18 N	Range: 12 E	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: REPLACE OLD 2"

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	160

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
N	S		N-FINE S-SAND	Surface	90
N	X		N-FINE X-SAND & CLAY	90	150
M	S		M-MEDIUM S-SAND	150	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, P/E, WELDED, NUCOR, .280 WALL, ASTMA53B.	Surface	154
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S. S. #10	154	160

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

75 ft. below ground surface

10. Pump Test

Pumping level 95 ft. below surface

Pumping at 25 GP M for 48 Hrs.

Pumping Method ? Other

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB	7036	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed
IA	9217	04-22-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75

Comment:

Created On: 04-22-2026 Updated On: 05-13-2026 Review Status: APPROVED