

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM791		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MC SWEENEY, MIKE						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 1934 DEERPATH RD						Town of STRONGS PRAIRIE						1934									
City ARKDALE						State WI		Zip Code 54613				Street Address or Road Name and Number DEERPATH RD									
County Adams		Co. Permit #		Notification # 10160373301		Completed 04-21-2026		Subdivision Name SUNSET RIDGE EST				Lot # 29		Block #							
Well Constructor (Business Name) MARSHALL WELL DRILLING CORP				Lic. # 6946		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9882 °N -89.9451 °W				Method Code GPS008							
Address 3774 ST RD 13 WISCONSIN DELLS WI 53965-8906				Well Plan Approval #				NW SE		Section 31		Township 18 N		Range 5 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 4		2. Well Type Replacement				of previous unique well # UN949 constructed in 2008											
Reason for replaced or reconstructed well ? LOW YIELD & VERY HIGH IRON CONTENT				Construction Type Drilled																	
3. Well serves 1 # of HOME						Hicap Well ? No															
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9.875		Surface		8		<u>No</u> Rotary - Mud Circulation				<u>No</u>		S		S-SAND		Surface		16			
6		8		120		<u>Yes</u> Rotary - Air				<u>Yes</u>		R M S		R-RED M-MEDIUM S-SAND		16		68			
						<u>No</u> Rotary - Air & Foam				<u>No</u>		R A Y		R-RED A-COARSE Y-SAND & GRAVEL		68		70			
						<u>No</u> Drill-Through Casing Hammer						S N		S-SOFT/LOOSE N-SANDSTONE		70		96			
						<u>No</u> Reverse Rotary						H N		H-HARD/FIRM N-SANDSTONE		96		120			
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>											
						<u>No</u> Dual Rotary				<u>No</u>											
						<u>No</u> Temp. Outer Casing ___ in. dia															
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		37 ft. below ground surface				18 in. above grade							
6		P.E. STEEL PIPE ASTM A-53 GR.B 18.97 LBS/FT WHEATLAND STEEL				Surface		96		10. Pump Test				Developed ? Yes							
										Pumping level 42 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 20 GP M for 72 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes							
Method GRAVITY																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes							
GRANULAR BENTONITE				Surface		8		6 S													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
JLJ														7213		04-24-2026					
Drill Rig Operator														Lic or Reg #		Date Signed					
RGW														7349		04-24-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		62	Sewer - Building Sanitary		15
Building Drain - Sanitary	>	13	Septic or Holding, or POWTS Tank		41

Comment:

Created On: 04-22-2026

Updated On: 05-22-2026

Review Status: APPROVED