Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM798

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PALCZYNSKI, TOMASZ			Phone #
Mailing Address: N9256 FLOOD RD			
City: MERRILLAN	State: WI	Zip Code: 54754	
County: Jackson	Co. Permit #: 26111-2	Notification #: 10234839901	Completed: 04-22-2026

Well Constructor (Business Name): OIUM, KELLY WELL DRILLING INC	Lic. #: 8217	Facility ID # (Public Wells)	
Address: N50021 MISSELL ROAD STRUM WI 54770		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ALMA					Fire # (if avail.): N9256
Street Address or Road Name and Number: FLOOD RD					
Subdivision Name: ENCHANTED WATERS SUBDIVISION			Lot #: 4		Block #
Latitude / Longitude in Decimal Degree (DD): 44.40463 °N -90.80272 °W					Method Code: GPS008
NE NE or Govt Lot #	Section: 12	Township: 22 N	Range: 4 W		

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	34
6	34	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	1
T	A	S		T-TAN/BROWN A-COARSE S-SAND	1	4
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	4	24
R	H	N	C	R-RED H-HARD/FIRM N-SANDSTONE C-CLAYEY	24	32
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	32	75
R	H	N		R-RED H-HARD/FIRM N-SANDSTONE	75	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	VICTOR PIPE & STEEL 6.620XA53B.280 EWTC	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	36	18 S

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO	6244	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JG	8980	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		36

Comment:

Created On: 04-22-2026 Updated On: 05-26-2026 Review Status: APPROVED