

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM798		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PALCZYNSKI, TOMASZ						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N9256 FLOOD RD						Town of ALMA						N9256			
City MERRILLAN						State WI		Zip Code 54754				Street Address or Road Name and Number FLOOD RD			
County Jackson		Co. Permit # 26111-2		Notification # 10234839901		Completed 04-22-2026		Subdivision Name ENCHANTED WATERS SUBDIVISION				Lot # 4		Block #	
Well Constructor (Business Name) OIUM, KELLY WELL DRILLING INC				Lic. # 8217		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.40463 °N -90.80272 °W				Method Code GPS008	
Address N50021 MISSELL ROAD STRUM WI 54770				Well Plan Approval #		NE NE		Section 12		Township 22 N		Range 4 W		or Govt Lot #	
Hicap Permanent Well #				Common Well #		Specific Capacity 1				2. Well Type New Well					
3. Well serves 1 # of HOME				Hicap Well ? No		of previous unique well # constructed in									
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		34		No Rotary - Mud Circulation				No					
6		34		80		No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						Yes Cable-tool Bit 10in. dia...				No					
						No Dual Rotary				Yes					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
T A S				I-SOIL-ORGANIC				Surface				1			
T H N				T-TAN/BROWN A-COARSE S-SAND				1				4			
R H N C				T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				4				24			
T H N				R-RED H-HARD/FIRM N-SANDSTONE C-CLAYEY				24				32			
R H N				T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				32				75			
				R-RED H-HARD/FIRM N-SANDSTONE				75				80			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		VICTOR PIPE & STEEL 6.620XA53B.280 EWTC				Surface		36							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		36		18 S							
9. Static Water Level															
40 ft. below ground surface															
10. Pump Test															
Pumping level 60 ft. below surface															
Pumping at 20 GP M for 2 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
KO				6244		04-27-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
JG				8980		04-27-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		36

Comment:

Created On: 04-22-2026

Updated On: 05-26-2026

Review Status: APPROVED