Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM804

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PAQUETTE MITCHELL	Phone #
Mailing Address: 2391 81 AVE	
City: OSCEOLA	State: WI Zip Code: 54020

County	Co. Permit #	Notification #	Completed
Polk		10223247403	04-21-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
STEVE'S WELL AND PUMP SERVICES, LLC	8260	

Address: 499 192ND AVE
SOMERSET WI 54025

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of OSCEOLA

Fire # (if avail.): 2391

Street Address or Road Name and Number: 81 AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.32602 °N	-92.64949 °W			SCR002

SW SW or Govt Lot #	Section	Township	Range
	19	33 N	18 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
LACK OF WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	44

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	25
T	X	C		T-TAN/BROWN X-LENSED/STREAKED/LAYERED C-CLAY	25	38
G	F	B	G	G-GRAY F-FRACTURED B-BASALT OR TRAP ROCK G-W/GRAVEL/STONES	38	44

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE 18.99 LBS FT WELDED ASTM	Surface	40
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	JOHNSON 12 SLOT SS	40	44

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	40	2 S

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 8 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
OTHER COMPANY TO DO

Filled & Sealed Well(s) as needed? Yes
OTHER COMPANY TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
SF	6412	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		75	POWTS dispersal component (soil absorption unit or mound)		85

Comment:

Created On: 04-22-2026 Updated On: 10-15-2026 Review Status: APPROVED