Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM807

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JEFFERY A. PASCH	Phone #
Mailing Address: 30565 COUNTY HIGHWAY A	
City: CAMP DOUGLAS	State: WI — Zip Code: 54618
County: Monroe	Co. Permit #: — Notification #: 10233195501 — Completed: 04-22-2026
Well Constructor (Business Name): SCHAITEL, JAKE J	Lic. #: 3822 — Facility ID # (Public Wells):
Address: TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of CLIFTON	Fire # (if avail.): 30565
Street Address or Road Name and Number: CTY A	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8849 °N -90.3818 °W	Method Code: SCR002
NW NE or Govt Lot #:	Section: 9 — Township: 16 N — Range: 1 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	14
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	14	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE BLACK STEEL ASTMA 53 A 19.85 280 WALL WELD WHEATLAND USA PIPE	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

43 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 3 Hrs.

Pumping Method ? Airlift

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	12 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JS	3822	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		121	POWTS dispersal component (soil absorption unit or mound)		81

Comment:

Created On: 04-22-2026 Updated On: 05-14-2026 Review Status: APPROVED