

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM807		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JEFFERY A. PASCH						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 30565 COUNTY HIGHWAY A						Town of CLIFTON						30565					
City CAMP DOUGLAS						State WI		Zip Code 54618				Street Address or Road Name and Number					
County Monroe						Co. Permit #		Notification # 10233195501				Completed 04-22-2026					
Well Constructor (Business Name) SCHAITE, JAKE J						Lic. # 3822		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8849 °N -90.3818 °W					
Address TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603						Well Plan Approval #		NW NE		Section 9		Township 16 N					
Hicap Permanent Well #						Common Well #		Specific Capacity 0.6				Range 1 E					
3. Well serves 1 # of HOME						Hicap Well ? No		2. Well Type New Well				of previous unique well # constructed in					
Private, potable						Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
10 Surface 40			No Rotary - Mud Circulation				No				T V C		T-TAN/BROWN V-NON-CAVING C-CLAY		Surface 14		
6 40 80			No Rotary - Air				No				T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		14 80		
			Yes Rotary - Air & Foam				Yes										
			No Drill-Through Casing Hammer														
			No Reverse Rotary														
			No Cable-tool Bit ___ in. dia...				No										
			No Dual Rotary				No										
			No Temp. Outer Casing ___ in. dia														
			No Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		43 ft. below ground surface		15 in. above grade				
6			NEW PE BLACK STEEL ASTM A 53 A 19.85 280 WALL WELD WHEATLAND USA PIPE				Surface		40		10. Pump Test		Developed ? Yes				
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface		Disinfected ? Yes				
											Pumping at 10 GP M for 3 Hrs.		Capped ? Yes				
											Pumping Method ? Airlift						
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No								
NEAT CEMENT GROUT			Surface		40		12 S										
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JS		3822		04-22-2026	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		121	POWTS dispersal component (soil absorption unit or mound)		81

Comment:

Created On: 04-22-2026

Updated On: 05-14-2026

Review Status: APPROVED