Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM808

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHMIDT, TODD	Phone #
Mailing Address: 4316 GROSBEAK GLEN	
City: WINDSOR	State: WI — Zip Code: 53598

County	Co. Permit #	Notification #	Completed
Jefferson		10232307901	04-21-2026

Well Constructor (Business Name): WEBSTER & SONS WELL DRILLING, LLC	Lic. #: 9242
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 415 N. MAIN STREET POYNETTE WI 53955	
Approval Date (mm-dd-yyyy)	

Hicap Permanent Well #	Common Well #	Specific Capacity: 3.6	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of OAKLAND

Fire # (if avail.): 8784

Street Address or Road Name and Number: 8787 BLUE VIOLET CT

Subdivision Name	Lot #	Block #
THE PRESERVE AT OAKLAND	22	

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.0111 °N	-88.9691 °W			GPS008

SW	SW	Section	Township	Range
or Govt Lot #		4	6 N	13 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.8	Surface	60
6	60	124

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F	C	F-FILL C-CLAYEY	Surface	4
		Z		Z-CLAY & GRAVEL	4	22
		Z	S	Z-CLAY & GRAVEL S-SANDY	22	33
	H	L		H-HARD/FIRM L-LIMESTONE/DOLOMITE	33	51
	H	N		H-HARD/FIRM N-SANDSTONE	51	60
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	60	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B PE .280 WALL	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	60	15 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 24 ft. below surface
Pumping at 18 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW	6890	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	175
Sewer - Collector - Sanitary	>	55
Building Drain - Sanitary	>	18
Sewer - Building Sanitary	>	15
Ditch or Culvert	>	40

Comment:

Created On: 04-22-2026 Updated On: 05-14-2026 Review Status: APPROVED