

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM808		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCHMIDT, TODD						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 4316 GROSBEAK GLEN						Town of OAKLAND		8784				Street Address or Road Name and Number					
City WINDSOR						State WI		Zip Code 53598				8787 BLUE VIOLET CT					
County Jefferson		Co. Permit #		Notification # 10232307901		Completed 04-21-2026		Subdivision Name THE PRESERVE AT OAKLAND				Lot # 22		Block #			
Well Constructor (Business Name) WEBSTER & SONS WELL DRILLING, LLC				Lic. # 9242		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0111 °N -88.9691 °W				Method Code GPS008			
Address 415 N. MAIN STREET POYNETTE WI 53955				Well Plan Approval #		SW SW		Section 4		Township 6 N		Range 13 E		or Govt Lot #			
Hicap Permanent Well #				Common Well #		Specific Capacity 3.6				2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No				Reason for replaced or reconstructed well ?			
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled				Reason for replaced or reconstructed well ?				Reason for replaced or reconstructed well ?			
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
8.8 Surface 60			Yes Rotary - Mud Circulation No														
6 60 124			No Rotary - Air Yes														
			No Rotary - Air & Foam No														
			No Drill-Through Casing Hammer														
			No Reverse Rotary														
			No Cable-tool Bit ___ in. dia... No														
			No Dual Rotary No														
			No Temp. Outer Casing ___ in. dia														
			No Removed? ___ depth ft. (If NO explain on back side)														
8. Geology																	
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...							From (ft.)		To (ft.)					
F C			F-FILL C-CLAYEY							Surface		4					
Z			Z-CLAY & GRAVEL							4		22					
Z S			Z-CLAY & GRAVEL S-SANDY							22		33					
H L			H-HARD/FIRM L-LIMESTONE/DOLOMITE							33		51					
H N			H-HARD/FIRM N-SANDSTONE							51		60					
T H N			T-TAN/BROWN H-HARD/FIRM N-SANDSTONE							60		124					
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				11. Well Is			
6		WHEATLAND A53B PE .280 WALL				Surface		60		19 ft. below ground surface				18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 24 ft. below surface				Disinfected ? Yes			
										Pumping at 18 GP M for 3 Hrs.				Capped ? Yes			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No			
Method BRADENHEAD																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT		Surface		60		15 S								Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller														Lic #		Date Signed	
RW														6890		04-22-2026	
Drill Rig Operator														Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	175	Building Drain - Sanitary	>	18
Sewer - Collector - Sanitary	>	55	Sewer - Building Sanitary	>	15
			Ditch or Culvert	>	40

Comment:

Created On: 04-22-2026

Updated On: 05-14-2026

Review Status: APPROVED