

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM810		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ARNDT, MIKE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W4966 JAY RD						Town of FREDONIA						W4966			
City FREDONIA						State WI		Zip Code 53021				Street Address or Road Name and Number W4966 JAY RD			
County Ozaukee		Co. Permit #		Notification # 10236617601		Completed 04-22-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) STEFFES, DANIEL J				Lic. # 6109		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.5278 °N -88.0338 °W				Method Code GPS008	
Address BADGER WELL DRLG N7900 LOCUST LN MT CALVARY WI 53057				Well Plan Approval #		SE SW		Section 6		Township 12 N		Range 21 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SHORT OF WATER									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		185		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Y		Y-SAND & GRAVEL				Surface		47							
Z		Z-CLAY & GRAVEL				47		51							
L		L-LIMESTONE/DOLOMITE				51		185							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ASTM A 53 B EXL TUBE 6.625 X .280 EL 20 PLAIN END				Surface		51							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface				4 S									
9. Static Water Level															
4 ft. below ground surface															
10. Pump Test															
Pumping level 20 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Airlift															
11. Well Is															
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? No EBERHARDT PLUMBING IS DOING THE ABANDONMENT AND PUMP SYSTEM															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
DS				6109		04-22-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
GM				6835		04-22-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	=	60

Comment:

Created On: 04-22-2026

Updated On: 05-14-2026

Review Status: APPROVED