Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM811

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PEDERSEN, MICHAEL	Phone #: (414)704-0169
Mailing Address: 2736 NAGAWICKA AVE	
City: DELAFIELD	State: WI — Zip Code: 53018

County	Co. Permit #	Notification #	Completed
Waukesha		10234332201	04-22-2026

Well Constructor (Business Name): HERR WELL DRILLING INC	Lic. #: 672	Facility ID # (Public Wells):
Address: W295 HERR RD DOUSMAN WI 53118-9407		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
City of DELAFIELD

Fire # (if avail.): 2736

Street Address or Road Name and Number: NAGAWICKA AVENUE

Subdivision Name	Lot #	Block #
MISSION RIDGE	15	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.0817 °N -88.398 °W	GPS008

NE SW or Govt Lot #	Section	Township	Range
	8	7 N	18 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
REPLACING SAND POINT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	36

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	I-SOIL-ORGANIC	Surface	5
Z	Z-CLAY & GRAVEL	5	12
Y	Y-SAND & GRAVEL	12	36

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPIC, STAINLESS STEEL, 18-SLOT, WITH PACKER AND NIPPLE INSTALLED	33	36

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
1 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 30 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
NONE

Filled & Sealed Well(s) as needed? Yes
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
ALO	6666	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed
NSD	8132	04-22-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		25

Comment:

Created On: 04-22-2026 Updated On: 05-14-2026 Review Status: APPROVED