Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM812

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STACY WADE	Phone #: (262)620-7302
Mailing Address: N12272 OLSON RD	
City: WAUSAUKEE	State: WI — Zip Code: 54177

County	Co. Permit #	Notification #	Completed
Marinette		10226290802	04-16-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ARNESON WELL DRILLING LLC	9278	

Address: 4680 WINDING CREEK TRAIL, ABRAMS WI 54101

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of WAUSAUKEE

Fire # (if avail.): N12272

Street Address or Road Name and Number: OLSON RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.4046 °N -87.963 °W	GPS008

SW NE or Govt Lot #	Section	Township	Range
	23	34 N	20 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
SANPOINT FAILED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	29

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	S	S	T-TAN/BROWN A-COARSE S-SAND S-SANDY	Surface	29
U	H	Q	Q	U-BLUE H-HARD/FIRM Q-GRANITE Q-W/GRANITE	29	29

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SILVER-LINE 6 INCH SDR21 ! PVC1120 ASTM D2241 200 PSI WELL CASING	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT STAINLESS STEEL SCREEN	25	29

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROIID QUICK GROUT	Surface	22	4 S

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
DAMA PLUMBING SEALED SANDPOINT

Filled & Sealed Well(s) as needed? Yes
DAMA PLUMBING TO FILL AND SEAL SANDPOINT

13. Constructor / Supervisory Driller	Lic #	Date Signed
LA	7408	04-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
RV	8926	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: DAMA PLUMBING INSTALLED THE PUMP AND DID WELL ABANDONMENT

Created On: 04-23-2026 Updated On: 05-14-2026 Review Status: APPROVED