Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM814

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JIM SPANGENBERG			Phone #: (414)217-2565
Mailing Address: W5662 HWY FF			
City: ELKART LAKE	State: WI	Zip Code: 53020	
County: Marinette	Co. Permit #:	Notification #: 10226290804	Completed: 04-17-2026

Well Constructor (Business Name): ARNESON WELL DRILLING LLC	Lic. #: 9278	Facility ID # (Public Wells):	
Address: 4680 WINDING CREEK TRAIL ABRAMS WI 54101		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of CABIN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of WAUSAUKEE

Fire # (if avail.): W7427

Street Address or Road Name and Number: LOST LAKE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.3992 °N	-87.962 °W			GPS008

SW	SE	Section	Township	Range
or Govt Lot #		23	34 N	20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	38

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	Y	S	T-TAN/BROWN H-HARD/FIRM Y-SAND & GRAVEL S-SANDY	Surface	38
U	H	Q	Q	U-BLUE H-HARD/FIRM Q-GRANITE Q-W/GRANITE	38	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SILVER-LINE 6 INCH SDR21 ! PVC1120 ASTM D2241 200 PSI WELL CASING	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT STAINLESS STEEL SCREEN	34	38

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROIID QUICK GROUT	Surface	31	4 S
#40 GRAVEL PACK	31	38	8 S

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LA	7408	04-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LA	7408	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: OWNER IS DOING HIS OWN PUMP INSTALL

Created On: 04-23-2026 Updated On: 05-14-2026 Review Status: APPROVED