

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM814		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner JIM SPANGENBERG				Phone # (414)217-2565		1. Well Location				Fire # (if avail.)	
Mailing Address W5662 HWY FF						Town of WAUSAUKEE				W7427	
City ELKART LAKE				State WI		Zip Code 53020				Street Address or Road Name and Number LOST LAKE RD	
County Marinette		Co. Permit #		Notification # 10226290804		Completed 04-17-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) ARNESON WELL DRILLING LLC				Lic. # 9278		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.3992 °N -87.962 °W		Method Code GPS008	
Address 4680 WINDING CREEK TRAIL ABRAMS WI 54101				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 23 34 N 20 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 1		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of CABIN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
8.75		Surface		38		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T H Y S T-TAN/BROWN H-HARD/FIRM Y-SAND & GRAVEL S-SANDY Surface 38 U H Q Q U-BLUE H-HARD/FIRM Q-GRANITE Q-W/GRANITE 38 38	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		SILVER-LINE 6 INCH SDR21 ! PVC1120 ASTM D2241 200 PSI WELL CASING				Surface		34		24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
5		12 SLOT STAINLESS STEEL SCREEN				34		38			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
BAROID QUICK GROUT		Surface		31		4 S					
#40 GRAVEL PACK		31		38		8 S					
9. Static Water Level											
15 ft. below ground surface											
10. Pump Test											
Pumping level 30 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
LA		Lic # 7408		Date Signed 04-23-2026							
Drill Rig Operator		Lic or Reg # 7408		Date Signed 04-23-2026							
LA		7408		04-23-2026							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: OWNER IS DOING HIS OWN PUMP INSTALL

Created On: 04-23-2026

Updated On: 05-14-2026

Review Status: APPROVED