Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM815

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MIKE WROBLESKI	Phone #: (630)272-4083
Mailing Address: 588 KOHLEY RD LISLE ILL	
City: LISLE	State: IL — Zip Code: 54114
County: Marinette	Co. Permit #:
Notification #: 10233353501	Completed: 04-20-2026
Well Constructor (Business Name): ARNESON WELL DRILLING LLC	Lic. #: 9278
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 4680 WINDING CREEK TRAIL ABRAMS WI 54101	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.1	

1. Well Location

Town of STEPHENSON	Fire # (if avail.): N8878
Street Address or Road Name and Number: LOUISA RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.2789 °N -88.0021 °W	Method Code: GPS008
NW NW or Govt Lot #:	Section: 3 — Township: 32 N — Range: 20 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40.5
6	40.5	50

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	S	S	T-TAN/BROWN A-COARSE S-SAND S-SANDY	Surface	37
T	F	N	N	T-TAN/BROWN F-FRACTURED N-SANDSTONE N-W/SANDSTONE	37	40.5
T	H	N	N	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	40.5	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. 18.97 WHEATLAND A-53	Surface	40.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROIID QUICK GROUT	Surface	40.5	5 S

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 50 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LA	7408	04-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LA	8926	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: BRIX PLUMBING TO INSTALL WATER SYSTEM

Created On: 04-23-2026 Updated On: 05-26-2026 Review Status: APPROVED