

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM816		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JEREMY SPIELMAN Phone #						1. Well Location				Fire # (if avail.)					
Mailing Address 25620 SOUTH WINDLAKE						Town of STEPHENSON				N9340					
City CRIVITZ						State WI		Zip Code 53185							
County Marinette		Co. Permit #		Notification # 10233353502		Completed 04-22-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ARNESON WELL DRILLING LLC				Lic. # 9278		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.3025 °N -88.2121 °W				Method Code GPS008	
Address 4680 WINDING CREEK TRAIL ABRAMS WI 54101				Well Plan Approval #		SW SE		Section 26		Township 33 N		Range 18 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				2. Well Type New Well					
3. Well serves 1 # of CABIN				Hicap Well ? No		of previous unique well #				constructed in					
Private, potable				Drillhole		Hicap Property ? No				Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		35		Yes Rotary - Mud Circulation				No					
No Rotary - Air						No									
No Rotary - Air & Foam						No									
No Drill-Through Casing Hammer															
No Reverse Rotary															
No Cable-tool Bit ___ in. dia...						No									
No Dual Rotary						No									
No Temp. Outer Casing ___ in. dia															
No Removed? ___ depth ft. (If NO explain on back side)															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T X X S				T-TAN/BROWN X-LENSED/STREAKED/LAYERED X-SAND & CLAY S-SANDY				Surface		35					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		SILVER-LINE 6 INCH SDR21 ! PVC1120 ASTM D2241 200 PSI WELL CASING				Surface		26							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		12 SLOT STAINLESS STEEL SCREEN				26		35							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BAROID QUICK GROUT				Surface		26		4 S							
#40 GRAVEL PACK				26		35		12 S							
9. Static Water Level															
12 ft. below ground surface															
10. Pump Test															
Pumping level 25 ft. below surface															
Pumping at 8 GP M for 4 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
LA				7408		04-23-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
LA				8926		04-23-2026									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: DAMA PLUMBING TO INSTALL PUMP

Created On: 04-23-2026

Updated On: 05-14-2026

Review Status: APPROVED