Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM816

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JEREMY SPIELMAN	Phone #
Mailing Address: 25620 SOUTH WINDLAKE	
City: CRIVITZ	State: WI / Zip Code: 53185
County: Marinette	Co. Permit #: / Notification #: 10233353502 / Completed: 04-22-2026
Well Constructor (Business Name): ARNESON WELL DRILLING LLC	Lic. #: 9278 / Facility ID # (Public Wells):
Address: 4680 WINDING CREEK TRAIL, ABRAMS WI 54101	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 0.6

1. Well Location

Town of STEPHENSON	Fire # (if avail.): N9340
Street Address or Road Name and Number: HIGHLINE RD	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 45.3025 °N -88.2121 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 26 / Township: 33 N / Range: 18 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CABIN

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	35

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	X	X	S	T-TAN/BROWN X-LENSED/STREAKED/LAYERED X-SAND & CLAY S-SANDY	Surface	35

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SILVER-LINE 6 INCH SDR21 ! PVC1120 ASTM D2241 200 PSI WELL CASING	Surface	26
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	12 SLOT STAINLESS STEEL SCREEN	26	35

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 8 GP M for 4 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROIID QUICK GROUT	Surface	26	4 S
#40 GRAVEL PACK	26	35	12 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LA	7408	04-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
LA	8926	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: DAMA PLUMBING TO INSTALL PUMP

Created On: 04-23-2026 Updated On: 05-14-2026 Review Status: APPROVED