

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM817		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner BRUDNICK, JAMIE					Phone #		1. Well Location Fire # (if avail.) Town of WOODVILLE W3306 Street Address or Road Name and Number DUNDAS ROAD				Subdivision Name Lot # Block #	
Mailing Address W3306 DUNDAS ROAD												
City KAUKAUNA			State WI	Zip Code 54130								
County Calumet	Co. Permit #	Notification # 10233343401		Completed 04-22-2026								
Well Constructor (Business Name) GROUND SOURCE LLC			Lic. # 9443	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.2344 °N -88.2043 °W				Method Code GPS008		
Address 3671 MONROE ROAD DEPERE WI 54115			Well Plan Approval #		SE NE Section Township Range		or Govt Lot # 3 20 N 19 E		2. Well Type Replacement of previous unique well # 8DU821 constructed in 1972 Reason for replaced or reconstructed well ? BAD CASING Construction Type Drilled			
			Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0								
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...			
9	Surface	258	Yes Rotary - Mud Circulation			No			C C-CLAY Surface 64			
6	258	500	No Rotary - Air			Yes			U Q H U-BLUE Q-CAVING H-SHALE 64 140			
			No Rotary - Air & Foam			No			Q H Q-CAVING H-SHALE 140 256			
			No Drill-Through Casing Hammer						L L-LIMESTONE/DOLOMITE 256 460			
			No Reverse Rotary						N N-SANDSTONE 460 500			
			No Cable-tool Bit ___ in. dia...			No						
			No Dual Rotary			No						
			No Temp. Outer Casing ___ in. dia									
			No Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level 282 ft. below ground surface			11. Well Is 24 in. above grade			
6	NEW PLN END BLK STEEL WELDED 18.97.280 A53 NUCOR			Surface	258	10. Pump Test Pumping level 360 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift			Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)							
7. Grout or Other Sealing Material												
Method BRADENHEAD												
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes PUMP INSTALLER WILL ABANDON 13. Constructor / Supervisory Driller Lic # Date Signed TS 6667 04-23-2026 Drill Rig Operator Lic or Reg # Date Signed CV 04-23-2026						
HIGH SOLIDS BENTONITE GROUT		Surface	258	14 S								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		120	POWTS dispersal component (soil absorption unit or mound)		200

Comment:

Created On: 04-23-2026

Updated On: 05-19-2026

Review Status: APPROVED