

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM834		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner LINDEMANN, DEBBIE Phone # (414)380-9312						1. Well Location				Fire # (if avail.)	
Mailing Address N55 W37046 ROLAND STREET						Town of OCONOMOWOC				N55 W37046	
City OCONOMOWOC State WI Zip Code 53066						Street Address or Road Name and Number ROLAND STREET					
County Waukesha		Co. Permit #		Notification # 10236638801		Completed 04-23-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HERR WELL DRILLING INC				Lic. # 672		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.1208 °N -88.4819 °W		Method Code GPS008	
Address W295 HERR RD DOUSMAN WI 53118-9407				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 33 8 N 17 E		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 2.9		Reason for replaced or reconstructed well ? REPLACING SAND POINT			
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		102		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) Y Y-SAND & GRAVEL Surface 25 N X N-FINE X-SAND & CLAY 25 83 Y Y-SAND & GRAVEL 83 102	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI				Surface		99		12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
6		TELESCOPIC, STAINLESS STEEL, 18-SLOT, WITH PACKER AND NIPPLE INSTALLED				99		102			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface							
9. Static Water Level											
18 ft. below ground surface											
10. Pump Test											
Pumping level 25 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ? Airlift											
12. Notified Owner of need to fill & seal ? Yes PUMP INSTALLER DOING Filled & Sealed Well(s) as needed? Yes PUMP INSTALLER DOING											
13. Constructor / Supervisory Driller				Lic #		Date Signed					
ALO				6666		04-24-2026					
Drill Rig Operator				Lic or Reg #		Date Signed					
NSD				8132		04-24-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-23-2026

Updated On: 05-22-2026

Review Status: APPROVED