Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM834

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LINDEMANN, DEBBIE	Phone #: (414)380-9312
Mailing Address: N55 W37046 ROLAND STREET	
City: OCONOMOWOC	State: WI — Zip Code: 53066
County: Waukesha	Co. Permit #:
Notification #: 10236638801	Completed: 04-23-2026

1. Well Location

Town of OCONOMOWOC	Fire # (if avail.): N55 W37046
Street Address or Road Name and Number: ROLAND STREET	
Subdivision Name	Lot # / Block #

Well Constructor (Business Name): HERR WELL DRILLING INC	Lic. #: 672	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 43.1208 °N -88.4819 °W	Method Code: GPS008
Address: W295 HERR RD, DOUSMAN WI 53118-9407		Well Plan Approval #	NE NE or Govt Lot #	Section: 33 — Township: 8 N — Range: 17 E
		Approval Date (mm-dd-yyyy)		

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
REPLACING SAND POINT

Construction Type: Drilled

3. Well serves 1 # of HOME	Hicap Well ? No	
Private,potable	Hicap Property ? No	
Heat Exchange____# of drillholes	Hicap Potable ? No	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.9

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	102

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	25
	N	X		N-FINE X-SAND & CLAY	25	83
		Y		Y-SAND & GRAVEL	83	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI	Surface	99
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPIC, STAINLESS STEEL, 18-SLOT, WITH PACKER AND NIPPLE INSTALLED	99	102

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
PUMP INSTALLER DOING

Filled & Sealed Well(s) as needed? Yes
PUMP INSTALLER DOING

13. Constructor / Supervisory Driller	Lic #	Date Signed
ALO	6666	04-24-2026
Drill Rig Operator	Lic or Reg #	Date Signed
NSD	8132	04-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		95	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-23-2026 Updated On: 05-22-2026 Review Status: APPROVED