Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM841

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ADMJ LLC			Phone #
Mailing Address: PO BOX 48			
City: CUSTER	State: WI	Zip Code: 54423	
County: Portage	Co. Permit #:	Notification #: 10213643101	Completed: 04-17-2026

Well Constructor (Business Name): DJ'S WATER SERVICE	Lic. #: 7072	Facility ID # (Public Wells):	
Address: 6522 OAK DR AMHERST WI 54406		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Village of ROSHOLT

Fire # (if avail.): 311

Street Address or Road Name and Number: 311 SECOND ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.6292 °N	-89.3033 °W			GPS008
SW NW or Govt Lot #	Section: 21	Township: 25 N	Range: 10 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
BRING UP TO CODE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	20
R	V	C		R-RED V-NON-CAVING C-CLAY	20	37
T	Q	S	U	T-TAN/BROWN Q-CAVING S-SAND U-MUDDY OR MURKY	37	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL A53B 18.97 WHEATLAND WELD	Surface	38
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	12 SLOT STAINLESS STEEL TELESCOPING	38	42

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	38	1 S

9. Static Water Level
14.6 ft. below ground surface

10. Pump Test
Pumping level 36 ft. below surface
Pumping at 17 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJFJ	6760	04-17-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7416	04-17-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary	>	25	Sewer - Building Sanitary	>	8

Comment:

Created On: 04-23-2026 Updated On: 05-13-2026 Review Status: APPROVED