

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM842		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SWANSON, TRAVIS				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 12834 CTY RD D						Town of WOOD RIVER				12834	
City GRANTSBURG				State WI		Zip Code 54840				Street Address or Road Name and Number CTY RD D	
County Burnett		Co. Permit #		Notification # 10233239201		Completed 04-22-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) CHELL WELL DRILLING				Lic. # 22		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.79499 °N -92.64199 °W		Method Code SCR002	
Address 1471 345TH AVE FREDERIC WI 54837				Well Plan Approval #		SE NW Section Township Range or Govt Lot # 7 38 N 18 W		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? BAD WATER/POINT			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		220		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam Yes Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
S		S-SAND				Surface		50			
P Z		P-HARDPAN Z-W/COBBLES/BOULDERS				50		140			
C		C-CLAY				140		200			
Z C		Z-CLAY & GRAVEL C-CLAYEY				200		218			
B		B-BASALT OR TRAP ROCK				218		220			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD				Surface		218			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
0		NONE									
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface									
9. Static Water Level											
12 ft. below ground surface											
10. Pump Test											
Pumping level 40 ft. below surface											
Pumping at 60 GP M for 1 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
18 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
DJC		6846		04-22-2026							
Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)	>	100

Comment: DELAYED SAMPLE

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	05/13/2026	

Created On: 04-23-2026

Updated On: 05-13-2026

Review Status: APPROVED