Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM843

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DREAM BUILDERS	Phone #
Mailing Address: W4057 FAIRLANE CIR	
City: MALONE	State: WI — Zip Code: 53049
County: Fond du Lac	Co. Permit #: — Notification #: 10141210902 — Completed: 04-23-2026
Well Constructor (Business Name): STEFFES, DANIEL J	Lic. #: 6109 — Facility ID # (Public Wells):
Address: BADGER WELL DRLG N7900 LOCUST LN MT CALVARY WI 53057	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of ELDORADO	Fire # (if avail.): N9537
Street Address or Road Name and Number: N9537 RIDGE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.8863 °N -88.5779 °W	Method Code: GPS008

NE	SW	Section	Township	Range
or Govt Lot #		3	16 N	16 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	125

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	62
G		Z		G-GRAY Z-CLAY & GRAVEL	62	98
		L		L-LIMESTONE/DOLOMITE	98	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A 53 B EXL TUBE 6.625 X .280 EL 20 PLAIN END	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 25 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		6 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DS	6109	04-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GM	6835	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-23-2026 Updated On: 05-18-2026 Review Status: APPROVED