

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM843		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DREAM BUILDERS						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W4057 FAIRLANE CIR						Town of ELDORADO						N9537	
City MALONE						State WI		Zip Code 53049				Street Address or Road Name and Number	
N9537 RIDGE RD						Subdivision Name				Lot #		Block #	
County Fond du Lac		Co. Permit #		Notification # 10141210902		Completed 04-23-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) STEFFES, DANIEL J				Lic. # 6109		Facility ID # (Public Wells)				43.8863 °N -88.5779 °W		GPS008	
Address BADGER WELL DRLG N7900 LOCUST LN MT CALVARY WI 53057				Well Plan Approval #		NE SW		Section 3		Township 16 N		Range 16 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7		2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled			
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		125		No Rotary - Mud Circulation				No			
						No Rotary - Air				Yes			
						No Rotary - Air & Foam				No			
						Yes Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...				No			
						No Dual Rotary				No			
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
R		C		R-RED C-CLAY				Surface		62			
G		Z		G-GRAY Z-CLAY & GRAVEL				62		98			
		L		L-LIMESTONE/DOLOMITE				98		125			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		ASTM A 53 B EXL TUBE 6.625 X .280 EL 20 PLAIN END				Surface		98					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface				6 S					
9. Static Water Level													
60 ft. below ground surface													
10. Pump Test													
Pumping level 75 ft. below surface													
Pumping at 25 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
DS				6109		04-23-2026							
Drill Rig Operator				Lic or Reg #		Date Signed							
GM				6835		04-23-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-23-2026

Updated On: 05-18-2026

Review Status: APPROVED