

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM847		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DOOR COUNTY DESIGN BUILD						Phone # (920)421-8000		1. Well Location				Fire # (if avail.)					
Mailing Address 317 N. 17TH DR								Town of LIBERTY GROVE				10703					
City STURGEON BAY						State WI		Zip Code 54235				Street Address or Road Name and Number LAKEWOOD LN.					
County Door		Co. Permit #		Notification # 10210017701		Completed 04-23-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WESLOW WATER SYSTEMS INC				Lic. # 6400		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.1908 °N -87.0536 °W				Method Code GPS008					
Address 1710 FLOWING WELLS CT SUAMICO WI 54173				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 2 31 N 28 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
12		Surface		6		<u>No</u> Rotary - Mud Circulation		<u>No</u>		Z		Z-CLAY & GRAVEL		Surface		5	
9		6		170		<u>Yes</u> Rotary - Air		<u>Yes</u>		L		L-LIMESTONE/DOLOMITE		5		242	
6		170		242		<u>No</u> Rotary - Air & Foam		<u>No</u>									
						<u>No</u> Drill-Through Casing Hammer											
						Reverse Rotary											
						<u>No</u> Cable-tool Bit ___ in. dia...		<u>No</u>									
						<u>No</u> Dual Rotary		<u>No</u>									
						<u>Yes</u> Temp. Outer Casing 6in. dia											
						<u>Yes</u> Removed? 10depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				11. Well Is 24 in. above grade			
6		P.E. A53 18.97# NUCOR WELDED				Surface		170		10. Pump Test Pumping level 100 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method		BRADENHEAD										Filled & Sealed Well(s) as needed? No					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT		Surface		170		35 S											
												13. Constructor / Supervisory Driller Lic # Date Signed A.W. 6172 04-24-2026 Drill Rig Operator Lic or Reg # Date Signed J.S. 9069 04-24-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		30	POWTS dispersal component (soil absorption unit or mound)		59

Comment:

Created On: 04-24-2026

Updated On: 05-22-2026

Review Status: APPROVED